

Style 1672 Insulated Wire.

---

Rating 105°C, 300 Volts.

---

Insulated Labeled or complying with manufacturer's AWM Procedure  
Singles having a minimum rating of 105°C, 300 V.

---

Covering PVC: From 5 to 40 mils may be irradiated.

---

\*Standard Appliance Wiring Material UL 758.

---

Instructions Detailed Examination.  
to UL The designation of the style used as the insulated single  
Representative shall be available and the UL Representative's tag shall  
indicate if the style is labeled. If the single is not  
labeled, the appropriate follow-up tests shall be  
conducted.

---

UL (4) Detailed Examination.  
\*Counter-Check (4) Horizontal Flame Test.  
Program

If the insulated single is not labeled, the appropriate  
follow-up tests shall be conducted.

---

\*Marking General.

---

Use Internal Wiring of Electronic Equipment.